

DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

From:
Dr.S.PORKODI.,MBBS.,DPH.,
Deputy Director of Health Services.
Cuddalore District Health Officer
Cuddalore.

To:
The Correspondent,
Sri Saraswathi Vidyalaya
International(CBSE) School,
T.S.No.9/9, Block.116, Ward No.E
Alichikudi to Vriddhachalam Road
Vriddhachalam & Taluk, Pin 606001.
Cuddalore District.


L.Dis.No. 881 / B2 / 2024 / Dated. 21 .03.2024

Sir,

Sub:- Education Institution- Sanitary Certificate- Sri Saraswathi
Vidyalaya International (CBSE) School, T.S.No.9/9,
Block.116, Ward No.E, Alichikudi to Vriddhachalam Road,
Vriddhachalam & Taluk, Pin- 606001. Cuddalore District.
Sanitary Certificate issued-Regarding

Ref:- Inspection report dated **-01.03.2024**. The Block Health
Supervisor, Primary Health Centre, Mangalampet.

The sanitary Certificate in respect of Sri Saraswathi
Vidyalaya International (CBSE) School, T.S.No.9/9, Block.116, Ward No.E
Alichikudi to Vriddhachalam Road Vriddhachalam & Taluk, Pin- 606001.
Cuddalore District. letter cited for the year **2023- 24** is duly countersigned.


Deputy Director of Health Services
Cuddalore.

Copy to the Block Health Supervisor Primary Health centre. Mangalampet.

SANITARY CERTIFICATE

(YEAR 2023-24)

APPENDIX – 3

(Chapter III Rule: 24)

Tamil Nadu Educational Rules

I hereby declare that I have inspected the SRI SARASWATHI VIDYALAYA INTERNATIONAL (CBSE) SCHOOL, T.S.NO.9/9, BLOCK. 116, WARD NO.E, ALICHIKUDI TO VRIDDHACHALAM ROAD, VRIDDHACHALAM & TALUK, PIN- 606001. CUDDALORE DISTRICT. building and premises on the day of **01.03.2024** and certify.


- : that the accommodation provided for each of the several classes is sufficient for the minimum number of pupil taught therein and is properly ventilated and lighted;
- : that the building is maintained in substantial repair;
- : that is neat and clean;
- : that the latrine arrangements are adequate and satisfactory;
- : that the supply of drinking water is protected and wholesome; and
- : that in all other necessary aspects the sanitation is Satisfactory.

Subject to condition

1. The Toilet and Urinals should be disinfected twice a day.
2. “One Time use Plastic” should not be used in the school premises
3. Tobacco prohibition board should be displayed in the school premises 60 x30 cm containing warning “**NO SMOKING AREA, SMOKING HERE IS AN OFFENCE**”
4. No sale tobacco within the radius of 100 meters of the educational institution (Head Master/Principal should ensure)
5. No sale of tobacco inside the premises of the institution.
6. No smoking or chewing of tobacco inside the premises of institution.
7. Effective from the certificate One year.(February-2025)


BLOCK HEALTH SUPERVISOR
Govt. Block Primary Health Centre
Mangalampet - 606 104
Vriddhachalam Tk, Cuddalore Dt.

// Counter signed/


District Health Officer
Cuddalore


21/3/24



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
DISTRICT WATER TESTING LABORATORY
Near No.10, Thirumalai Nagar, Subburayulu Nagar Extension,
Cuddalore - 607001

E-mail : jwacudlab@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2024/898	Report Issue Date :	27.06.2024	Page No : 01 of 01		
Invoice Details:	323/Dt.24.06.2024 Amt.Rs.1652/-	ULR No :				
Client Name & Address Contact No / Email.ID		Sri Saraswathi Vidhyalaya International School, No.16, Alichikudi Road, Vriddahchalam, 606 001.				
Sample		Water				
Sample Number		898				
Sample Description		Drinking water @ Alichikudi Road,				
Sample Submitted by		Dr. E. K. Suresh				
Location & Date		Alichikudi Road & 24.06.2024				
Quantity of sample Received		2 Litre				
Sample Container		Jerry Cane				
Sample Condition on Receipt		Good				
Sample Received On		24.06.2024				
Test Commenced on		24.06.2024				
Test Completed on		25.06.2024				
Environmental Condition		23.0°C – 27.0°C				
S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2019)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25° C	-	IS 3025 Part :11:2022	6.7	6.5-8.5	6.5-8.5
2	Total Hardness as CaCO ₃	mg/L	IS 3025 (Part 21):2019	8.9	200	600
3	Total Alkalinity as CaCO ₃	mg/L	IS 3025-Part:23:2023	4.0	200	600
4	Chloride as Cl	mg/L	IS 3025-Part 32:2019	9.9	250	1000
5	Sulphate as SO ₄	mg/L	IS 3025-Part 24 Sec 1:2022	<5	200	400
6	Nitrate as NO ₃	mg/L	APHA 24th Edition 4500-NO ₃ B:2023	<2	45	45
7	Fluoride as F	mg/L	APHA 24th Edition 4500-F-D:2023	<0.2	1.0	1.5

Remark: The tested sample meet the requirement of IS: 10500:2012 (RA: 2019) Drinking water specification with respect to above tested parameters. The Decision rule is not applicable.

.....End of the report.....


Chemist
(Out Source)


Authorised Signatory
K. Ananthi
Junior Water Analyst

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
DISTRICT WATER TESTING LABORATORY
Near No.10, Thirumalai Nagar, Subburayulu Nagar Extension,
Cuddalore - 607001

E-mail : jwacudlab@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:		TR/2024/898	Report Issue Date :		27.06.2024	Page No : 01 of 01	
Invoice Details:		323/Dt.24.06.2024					
S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012		
					Acceptable Limit	Permissible Limit in the absence of alternate source	
1	Appearance	Visual observation	--	Clear	Clear	Clear	
2	Odour	IS 3025 Part 5 : 1983	--	Agreeable	Agreeable	Agreeable	
3	Turbidity	APHA 23rd Edition 2017 - 2130 B	NTU	0	1	5	
4	Total Dissolved Solids	APHA 23rd Edition 2017 – 2540 C	mg/L	30	500	2000	
5	Conductivity	APHA 23rd Edition 2017 – 2510 B	µS/cm	44	-	-	
6	P - Alkalinity	IS 3025–Part 23-1983	mg/L	NIL	-	-	
7	Calcium as Ca	APHA 23rd Edition 2017 – 3500 Ca B	mg/L	3	75	200	
8	Magnesium as Mg	APHA 23rd Edition 2017– 3500 Mg B	mg/L	2	30	100	
9	Iron as Fe	APHA 23rd Edition 2017– 3500 Fe B	mg/L	0	0.3	1	
10	Manganese as Mn	APHA 23rd Edition 2017 – 3500 Mn B	mg/L	<0.1	0.1	0.3	
11	Ammonia as NH ₃	APHA 17th Edition-1989– 4500 NH ₃ C	mg/L	0	0.5	0.5	
12	Nitrite as NO ₂	APHA 23rd Edition 2017– 4500-NO ₂ B	mg/L	< 0.01	-	-	
13	Total Phosphate as PO ₄	APHA 23rd Edition 2017 – 4500 P- D	mg/L	0	-	-	
14	Tidys 4 hr. test	APHA 23rd Edition 2017 – 4500 O - B	mg/L	0.4	-	-	

Report: The water sample meet the requirement of IS10500:2012 with respect to the parameters tested.


Chemist

(Out Source)

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.


Junior Water Analyst,
District Water Testing Laboratory,
Cuddalore.