

FORM - D

Form of License under sub-section 6 of the Madras public building (licensing) Act 1965 (Madras Act 13 of 1965) referred in Rule 6 of the Madras public Building (Licensing) Rules 1966.

LICENSE

License No: 18/2024

Fee Rs.500 SBI Vriddhachalam.


Dated:26.03.2024

Registration No:K.Dis.A2/743/2024

Dt.07.05.2024

License is hereby granted to **Sri Saraswathi Vidhyalaya International School, (Ward-E, Block 116, T.S.No:9/9, No:16, Alichikudi Road, Vriddhachalam, Cuddalore District – 606001)** for the purpose and in respect of the building specified in the statement below and subject to the conditions and for the period mention hereunder :-

1. The period of validity of the License shall be from **01.06.2023 to 31.05.2026** (Both Days Inclusive)
2. The building should be use the Purpose for which License has been granted.
3. The number of persons to be accommodated in the building should not exceed the number noted in Col.3, of the statement in the license at a time.
4. This license will not be valid for any addition or alternation made to this building before the date of expiry of the period of the license.
5. Fresh license will have to be obtained if any additions or alternations are made to this building.


**TASHILDAR
VRIDDHACHALAM.**

STATEMENT OF ACCOMPANY THE LICENSE


7.5.2024

Location of the building (Door No, Street No, and Name of Place)	Purpose for which the building is licensed to be used as a public building	No.of Persons to be Accommodated
Sri Saraswathi Vidhyalaya International School, (Ward-E, Block 116, T.S.No:9/9) No:16, Alichikudi Road, Vriddhachalam, Cuddalore District – 606001.	Educational Purpose	Students : 1000 Staff : 80




**TASHILDAR
VRIDDHACHALAM.**


07.05.2024

Er.K.G.MANIVACHAKAM,B.E.,M.I.E.,F.I.V.,

Class IA Registered Engineer. (PANEL REG.No.AEE/TI/B/94630-96.Competent person to release structural soundness Certificate for public buildings, Chartered Engineer (India) IIE(REG.No.M-111304/0), PPE IV- REG.No.F-10285, Reg.No.under section 34AB of Wealth Tax Act - Category I/566 of 2002 - 2003, Approved Valuer/Civil Engineer, Panel Valuer of Banks

Annexure D

BUILDING SAFETY CERTIFICATE

No.24624

Dated : 24-06-2024

It is certified that the existing building Sri Saraswathi Vidyalaya International School, Alichikudi to Virudhachalam Road, T.S.No.9/9,Block .116, Ward No.E, Virudhachalam Municipal Limit,Virudhachalam Town and Taluk,Cuddalore District.is having block(s) Floor(s) as per details below :

Detail of Block(s) in School	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (5)
No. of Floor(s) in the block	G+2	N.A.	N.A.	N.A.	N.A.	N.A.

The building is owned /occupied by Sri Saraswathi Vidyalaya International School, have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of Er.K.G.Manivachakam, Class-1A Panel Engineer (Under Tamilnadu Public building Lic.Act.) Collecterate Panel Engineer on 21-06-2024 in the presence of, Dr.E.K.Suresh Chairman, Sri Saraswathi Vidyalaya International School, Alichikudi to Virudhachalam Road, Virudhachalam Municipal Limit,Virudhachalam Town and Taluk,Cuddalore District and that the building/ premises is fit for occupancy for running school with effect from 01-06-2023 to 31-05-2026 for a period of Three years in accordance with rule and subject to compliance of the specific conditions as appended.

1. The campus consists of one block only
2. This block is having G+2 floor only
3. The plinth area of the building is G.F :786.21 Sq.M and F.F : 807.81 Sq.M and S.F: 801.35 Sq.M.
4. Year of the construction : 2010
5. Maintenance of the building work are to be carried out periodically

Issued on 24-06-2024 at Cuddalore -1 by Er.K.G,Manivachakam

Signature with Seal

Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V., C.E.
CLASS - IA REGISTERED ENGINEER,
(Under Tamil Nadu Public Building Lic.Act.)
COLLECTERATE PANEL ENGINEER,
Chartered Engineer, Approved Valuer,
D.No: 3/201, First Cross Street, Friends Nagar,
SEMMANDALAM, CUDDALORE - 607 001.

Address : 3/201, Ist Cross street, Friends Nagar, Cuddalore -607 001.

Er.K.G.MANIVACHAKAM,B.E.,M.I.E.,F.I.V.,

Class IA Registered Engineer, (PANEL REG.No.AEE/T1/B/94630/96, Competent person to release structural soundness Certificate for public buildings, Chartered Engineer (India) IEI(REG.No.M-111304/0), PPE IV- REG.No.F-10285, Reg.No.under section 34AB of Wealth Tax Act – Category I/566 of 2002 – 2003, Approved Valuer/Civil Engineer, Panel Valuer of Banks

Certificate of Structural Soundness for the School

Statement accompanying the Form-A.

1. Door Number of building : Sri Saraswathi Vidyalaya International School
2. Location (Street, Name, Ward Number, Name of place, i.e. Corporation/Municipality/ Panchayat/Panchayat Union/Township/ Contonment, etc.,) : Alichikudi to Virudhachalam Road
T.S.No.9/9
Block .116, Ward No.E,
Virudhachalam Municipal Limit
Virudhachalam Town and Taluk
Cuddalore District.
3. Year of construction : 2010
4. Approximate cost of construction as per current rates : Rs.2,60,00,000-
(Rs.Two crores and sixty lakhs only)
5. Purpose for which the building is being used or proposed to be used : Class rooms, Office, Staff room, Library, Composite science lab, Maths lab and Toilets
6. Purpose for which the building has now been used : -do-
7. Details of construction of the building (particulars of the foundation soil, specification of the various parts under) :
 - a) Foundation : RCC footings
 - b) Basement : Brick masonry with cement mortor.
 - c) Superstructure : Brick masonry with cement mortor
 - d) Floor and roof, are to be given : Cement mortar flooring and Ceramic tiles flooring and RCC roof slab

Address : 3/201, 1st Cross street, Friends Nagar, Cuddalore - 607 001

Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V. Ctny
CLASS - IA REGISTERED ENGINEER,
(Under Tamil Nadu Public Building Lic. Act.)
COLLECTORATE PANEL ENGINEER,
Chartered Engineer, Approved Valuer,
Registered Structural Engineer,
Reg. No: RSE / Gr-II / VR / MAY-2019 /007
Villupuram Region,
D.No: 3/201, First Cross Street, Friends Nagar
SEMMANDAIAM, CUDDALORE 607-001

Er.K.G.MANIVACHAKAM,B.E.,M.I.E.,F.I.V.,

Class IA Registered Engineer, (PANEL REG.No.AEE/T1/B/94630/96, Competent person to release structural soundness Certificate for public buildings, Chartered Engineer (India) IEI(REG.No.M-111304/0), PPE IV- REG.No.F-10285, Reg.No.under section 34AB of Wealth Tax Act – Category I/566 of 2002 – 2003, Approved Valuer/Civil Engineer, Panel Valuer of Banks

e) Area of the building	:	Sq.Ft.	Sq.M.
Ground floor		7660.15	711.91
Portico – 2 Nos		799.47	74.30
First floor		8692.04	807.81
Second floor		8622.53	801.35

8. Period for which licence is required : From 01-06-2023 to 31-05-2026

9. Number of persons to be accommodated : 1000 Nos (Capacity)

“ Certified that no addition or alteration has been made to the existing (Sri Saraswathi Vidyalaya International School, Alichikudi to Virudhachalam Road, T.S.No.9/9, Block .116, Ward No.E, Virudhachalam Municipal Limit, Virudhachalam Town and Taluk, Cuddalore District.) building or portion of a building for which this application has been made. I undertake to obtain a fresh licence in case any addition or alteration is made to the existing building or portion of building. I also undertake to obtain a fresh licence if the purpose for which the licence was granted for the use of the building or a portion of the building originally is changed or altered subsequently.

Date :

Signature of the owner of the building

Date : 09-05-2023

Signature of the Registered Engineer

Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V. C.Eng
CLASS - IA REGISTERED ENGINEER,
(Under Tamil Nadu Public Building Lic. Act.)
COLLECTORATE PANEL ENGINEER,
Chartered Engineer, Approved Valuer,
Registered Structural Engineer,
Reg. No: RSE / Gr-II / VR / MAY-2019 / 007
Villupuram Region,
D.No: 3/201, First Cross Street, Friends Nagar
SEMMANDALAM, CUDDALORE 607 001

Address : 3/201, 1st Cross street, Friends Nagar, Cuddalore -607 001.(TN)

Er.K.G.MANIVACHAKAM,B.E.,M.I.E.,F.I.V.,

Class IA Registered Engineer, (PANEL REG.No.AEE/T1/B/94630/96, Competent person to release structural soundness Certificate for public buildings, Chartered Engineer (India) IEI(REG.No.M-111304/0), PPE IV- REG.No.F-10285, Reg.No.under section 34AB of Wealth Tax Act – Category I/566 of 2002 – 2003, Approved Valuer/Civil Engineer, Panel Valuer of Banks

Form –B

(Form of Certificate of structural soundness under sub-section (4) of section 4 of the Tamil Nadu Public Buildings (Licensing) Act. 1965 (Tamil Nadu Act. 13 of 1965) referred to in rule 4 of the Tamil Nadu Public Buildings (licensing) Rules . 1966).

I certify that I have inspected the building of Sri Saraswathi Vidyalaya International School, Alichikudi to Virudhachalam Road, T.S.No.9/9, Block .116, Ward No.E, Virudhachalam Municipal Limit, Virudhachalam Town and Taluk, Cuddalore District. mentioned in the statement and furnish below its salient technical features and the same is based on the data measurements and specifications found in the site of the subject school physically.

I. Foundation :

- | | | |
|--|---|-------------------|
| 1. Depth below Ground level | : | 1.83 M. |
| 2. Nature of soil met with at foundation level | : | Sandy clay |
| 3. Pressure at foundation | : | 7.00 M.Ton/Sq.M. |
| 4. Probable safe bearing capacity of the soil met with at foundation | : | 15.00 M.Ton/Sq.M. |

II. Super structure :

- | | | |
|--|---|---|
| 1. Maximum stress in the most critical section of masonry and concrete | : | 1600 Kg.Sq.Cm. |
| 2. Nature of masonry and concrete and its permissible stress | : | Brick masonry with cement mortor-3000 ksc and Concrete – 5000 ksc |

The structural soundness of the building has been verified by me with reference to ISI loading standards 878 (Latest version) and other relevant Indian Standards Code of practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A licence may be granted for the period from 01-06-2023 to 31-05-2026

Date : 09-05-2023

Address : 3/201, 1st Cross street, Friends Nagar, Cuddalore - 606001

Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V. C.Eng.
CLASS - IA REGISTERED ENGINEER,
(Under Tamil Nadu Public Building Lic. Act.)
COLLECTORATE PANEL ENGINEER,
Chartered Engineer, Approved Valuer,
Registered Structural Engineer,
Reg. No: RSE / Gr-II / VR / MAY-2019 / 007
Villupuram Region,
D.No: 3/201, First Cross Street, Friends Nagar
SEMMANDALAM, CUDDALORE 607 001

Er.K.G.MANIVACHAKAM,B.E.,M.I.E.,F.I.V.,

Class IA Registered Engineer, (PANEL REG.No.AEE/T1/B/94630/96, Competent person to release structural soundness Certificate for public buildings, Chartered Engineer (India) IEI(REG.No.M-111304/0), PPE IV- REG.No.F-10285, Reg.No.under section 34AB of Wealth Tax Act – Category I/566 of 2002 – 2003, Approved Valuer/Civil Engineer, Panel Valuer of Banks

Form – C

Statement to accompany The Certificate of Structural Soundness

1. Location of the building, door number, street and name of the : Sri Saraswathi Vidyalaya International School
Alichikudi to Virudhachalam Road
T.S.No.9/9
Block .116, Ward No.E,
Virudhachalam Municipal Limit
Virudhachalam Town and Taluk
Cuddalore District.
2. Age of the building : 13 years
3. Number of Storeys : Three Storeyed
4. Short description of structures steel/ Rcc framed or load bearing masonry : RCC framed structure
5. Purpose for which the building is certified for use : Class rooms, Office, Staff room, Library,
Composite science lab, Maths lab and Toilets
6. The period for which the building will be structurally sound : 3 years (from 01-06-2023 to 31-05-2026)
7. Number of persons to be accommodated : 1000 Nos (capacity)
8. Remarks : The building is structurally Sound and stable

Date : 09-05-2023

Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V. C.Eng.
CLASS - IA REGISTERED ENGINEER,
(Under Tamil Nadu Public Building Lic. Act.)
COLLECTORATE PANEL ENGINEER,
Chartered Engineer, Approved Valuer,
Registered Structural Engineer,
Reg. No: RSE / Gr-II / VR / MAY-2019 /007
Villupuram Region,
No: 3/201, First Cross Street, Friends Nagar,
EMMANDALAM, CUDDALORE 607 001

Address : 3/201, 1st Cross street, Friends Nagar, Cuddalore -607 001.(TN)

Er.K.G.MANIVACHAKAM,B.E.,M.I.E.,F.I.V.,

Class IA Registered Engineer, (PANEL REG.No.AEE/T1/B/94630/96,Competent person to release structural soundness Certificate for public buildings, Chartered Engineer (India) IEI(REG.No.M-111304/0), PPE IV- REG.No.F-10285, Reg.No.under section 34AB of Wealth Tax Act – Category I/566 of 2002 – 2003, Approved Valuer/Civil-Engineer,Panel Valuer of Banks

Form – E

(Form of report to be made to the competent authority by inspecting authorities or officers appointed under other Act Under Section 28 of the Madras Public Buildings Licensing) Act. 1965 (Madras Act 13 of 1985) referred to in rule 7 of the Madras Public Building Licensing Rules. 1966.

- | | | |
|--|---|---|
| 1.Name and designation of inspecting authority or officer appointed or having jurisdiction under any other Act or law | : | Er.K.G.Manivachakam
B.E.,M.I.E.,F.I.V.,
Registered Engineer Class I.A
3/201,Ist Cross Street
Friends Nagar
Cuddalore – 607 001. |
| 2. Location of the building inspected
D.No. Street No. Name of place i.e.
Municipal corporation / Municipality/
Panchayat or Panchayat Union/
Township/Contonment. | : | Sri Saraswathi Vidyalaya International School
Alichikudi to Virudhachalam Road
T.S.No.9/9
Block .116, Ward No.E,
Virudhachalam Municipal Limit
Virudhachalam Town and Taluk,
Cuddalore District |
| 3. Date of Inspection | : | 02-05-2023 |
| 4. Purpose for which the building is used | : | Class rooms, Office, Staff room,Library,
Composite science lab,Maths lab and Toilets |
| 5. Nature of defects noticed | : | Nil |
| 6. Suggestion of rectifying defects | : | Nil |
| 7. If in a dangerous condition immediate action recommended to be taken | : | Nil |

Date : 09-05-2023


Er. K.G. MANIVACHAKAM, B.E.,M.I.E.,F.I.V. C.Eng
CLASS - IA REGISTERED ENGINEER,
(Under Tamil Nadu Public Building Lic. Act.)
COLLECTORATE PANEL ENGINEER,
Chartered Engineer, Approved Valuer,
Registered Structural Engineer,
Reg. No: RSE / Gr-II / VR / MAY-2019 /007
Villupuram Region,
D.No: 3/201, First Cross Street, Friends Naga-
EMMANDALAM, CUDDALORE 607 00

Address : 3/201, Ist Cross street, Friends Nagar, Cuddalore

Proceedings of the Collector of South Arcot Vallalar District.

Present: Thiru I. Shanmugam, I.A.S.,
-:000:-

D.O. No. 2/6377/96

Dated: 23.4.96

Sub: Tamil Nadu Public Building Licensing Act 1965 -
Inclusion of the name of Thiru G. Manivachakam
in the panel of Private Practising Engineer
under class I-A in South Arcot Vallalar District.

Ref: 1. Petition of Thiru Manivachakam, dated 9.10.95
2. Proceedings No. AEE/T/1/94630/96, dated
25.3.96 of the Engineer in Chief WRO, Public
Works Department, Madras.
3. G.O. No. 622, dated 7.4.77, Rural Development
& Local Administration Department.

Thiru G. Manivachakam, B.E. (Civil) has presented an application to the Collector of South Arcot Vallalar District, Cuddalore for registering his name in the panel of Engineers under Class I-A category. In this connection his application was forwarded to the Chief Engineer, Public Works Department, Madras through Superintending Engineer, P.W.D., Cuddalore.

The Board of Engineers in the 346th meeting held on 30.1.96 has recommended to include his name in the panel of private practising engineers under class I-A for the South Arcot Vallalar District.

Accordingly the name of Thiru G. Manivachakam is ordered to be included in the panel of Private Practising Engineers under Class I-A for the South Arcot Vallalar District for the purpose of issuing structural soundness certificates for public buildings (the cost of which is more than Rs. 10.00 lakhs) under the purview of the Tamil Nadu Public Building Licensing Act, 1965 and rules.

To
Thiru G. Manivachakam, B.E. (Civil)
Civil Engineering Consultant/Construction Engineer,
201, First Cross Street,
Friends Nagar (Opp. Dist. Employment Office)
Cuddalore.

0-17/2/96/101
Thiru G. Manivachakam (General)
to the Collector of South Arcot
Vallalar District, Cuddalore.

Copy to: 1. The Member Secretary, Local Planning Authority, Cuddalore - for information.
2. The Chief Educational Officer, Cuddalore - for information.
3. The Executive Engineer, P.W.D., Cuddalore - for information.

4. All the Municipal Commissioners of South Arcot Vallalar District.

Copy to 'C' Section, Collectorate, Cuddalore - for information.

5. The President, Theatre Owners' Association for information.

6. The District Microvideo Welfare Officer, Cuddalore.

7. The Project Officer, D.R.D., Cuddalore.

8. The District Assistant (I.D.)

Attended
Proceedings No AEE/T/1/96
4630/96
25-3-96
Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V. C. Eng
(Under Tamil Nadu Public Building Lic. Act.)
REGISTERED ENGINEER
Chartered Engineer, Approved Valuer,
Registered Structural Engineer,
Reg. No: RSE / Gr-II / VR / MAY-2019 / 007
Villupuram Region,
D.No: 3/201, First Cross Street, Friends Nagar
SEMMANDALAM, CUDDALORE 607 001

* G.O. Ms. No. 43, Municipal Administration and Water Supply (MA 4), February 17, 2011 – Published in the Tamil Nadu Government Gazette, Part III, Section 1(a), Issue No.9 Page 26-27, dated March 9, 2011

111-A. Registration of Engineers in the Panel:-
Private Engineers possessing the qualifications specified in the table may register their names in one or more districts or in all districts subject to inclusion of their names in the Panel of Registered Engineers for the District concerned.

The panel of Engineers shall be published in the Tamil Nadu Government Gazette and in the District Gazette concerned.]

Reg. No: RSE / Gr-II / VR / MAY-2014 / 007